



HORIZONTAL INSTALLATION (ALTERNATIVE)

- NOTE :-
- POLYSTEEL STAND PIPE SHALL BE :
 - 25 DIA. FOR 2 NOS. OF METERS OR
 - 50 DIA. FOR 3 OR MORE NOS. OF METERS

**TYPICAL DETAILS OF POLYSTEEL METER STAND
INSTALLATION FOR MULTI METER CONNECTION**

- NOTES:
- ALL DIMENSIONS ARE IN MILLIMETRE AND LEVELS ARE IN METRE UNLESS OTHERWISE STATED.
 - ACTUAL LENGTH OF COMMUNICATION PIPE SHALL BE DETERMINED ON SITE.
 - ALL CONCRETE TO BE GRADE 25 UNLESS OTHERWISE STATED.
 - ALL STAINLESS STEEL PIPES SHALL BE OF GRADE 304 TO SCHEDULES 40S.
 - ALL STAINLESS STEEL PIPES SHALL BE SOURCED FROM SUPPLIERS/ MANUFACTURERS APPROVED BY SPAN.
 - ACTION WILL BE TAKEN AGAINST PLUMBER/CONTRACTOR/CONSULTANT/ DEVELOPERS FOUND USING UNAPPROVED MATERIALS.



SURUHJANJAYA PERKHEIDMATAN AIR NEGARA
 Area Bawah & Atas Sulu
 Jalan Persegi, Blok 3/10
 63200 Chebeling
 Selangor Darul Ehsan, Malaysia

PREPARED BY :

MINCONSULT SDN. BHD.
 No. 4810, Jalan 1/77A,
 48100 SETIAJAYA,
 SELANGOR DARUL EHSAN, MALAYSIA.
 m i n c o
 TEL 03-79879757 / 79847273
 FAX 03-79879753

DRAWING TITLE:

METER STAND FOR MULTI
 METER CONNECTION
 - POLYSTEEL PIPE

DRAWING NO.

SPANWS/STD/034